



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

July 23, 2004
Subject: Lubec-Campobello
Pin No. 006893.00
Project No. BH-STP-6893(00)X
Bid Amendment No. 2

Dear Sir/Ms.:

The Department has received the following Requests for Information:

Question 1: Does "Buy America" Act apply or is it waived?

Response: The "Buy America" Act does apply.

Question 2: What is the maximum allowable concrete pour pressure for the steel column forms?

Response: The Contractor can not deform the steel column forms with their operations. The Contractor will need to assure that the steel column forms are properly braced as not to cause the welds to fail or the steel column forms to deform.

Consider this information prior to submitting your bid on July 28, 2004.

Sincerely,

Diane Barnes for

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER